

CERTIFICATE

The company

BRAMAC Dachsysteme International GmbH

Bramac Straße 9
3380 PÖCHLARN
AUSTRIA

with its production site in

Kirchdorf/Krems

hereby receives the confirmation that the product/s

Solar collectors

of the type

Bramac SolarDach BSD4E, BSD6E, BSD8E, BSD10E


conforms to

DIN EN 12975-1:2006-06

DIN EN 12975-2:2006-06

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products (Edition: 2003-01)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S561 F



DAP-ZE-2460.00

This certificate remains valid as long as the required surveillance conditions will be passed with a positive result for the assessment.


See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2008-11-03

Dipl.-Ing. Dipl.-Wi.-Ing. Sören Scholz
- Head of Certification Body -



Annex

to the Certificate with Registration No. 011-7S561 F, dated 2008-11-03

Technical data

See data sheet, part of the test report of 2008-10-23

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Österreichisches Forschungs-
und Prüfzentrum
Arsenal Ges. m.b.H.
Giefinggasse 2
1210 WIEN
OESTERREICH

Test report(s)

No. 2.04.00580.1.0-QT, No. 2.04.00580.1.0-LT dated 2008-10-23